

OP720

Declaration of performance No UKP210393

English – EN 2

Zug, 2022-03-07
Siemens Schweiz AG

.....
Dr. Peter Nebiker
Head of Fire Safety

.....
Irina Penzo Feliu de Cabrera
Quality Manager Fire Safety

Declaration of performance No UKP210393

This declaration of performance has been issued on the basis of the Construction Products Regulations 2013 and has no significance beyond this context. In particular, without limitation, this declaration does not contain any legal relevant declarations, such as in respect to quality, durability, usability, or warranty and liability commitments of any kind. These aspects are subject to agreement on a case-by-case basis at the time when the contract is concluded. The safety information in the applicable product documentation must be observed. You can obtain the latest version of the product documentation, as well as the declarations of performance and declarations of conformity, by contacting the Customer Support Center on +49 89 9221-8000 or by visiting <https://siemens.com/bt/download>.

Product type:

OP720

Product description:

Point type smoke detector incl. short-circuit isolator

Product variants:

OP720

Components:

DB721 DB722 DBS720

Intended use/es:

Fire safety, fire detection and fire alarm installations installed in and around buildings.

Manufacturer:

Siemens Schweiz AG, Theilerstrasse 1a, CH-6300 Zug

System/s of AVCP:

System 1

Harmonised standard:

EN 54-7:2018 | EN 54-17:2005 + AC:2007

Notified body/ies:

0832, BRE Global Limited

Declared performance/s:

| EN 54-7:2018 | | |
|--------------------------------------------------|---------|-------------|
| Essential characteristics | Section | Performance |
| Operational reliability | | |
| Individual alarm indication | 4.2.1 | Provided |
| Connection of ancillary device | 4.2.2 | Provided |
| Monitoring of detachable detectors | 4.2.3 | Provided |
| Manufacturer's adjustments | 4.2.4 | Provided |
| On-site adjustment of response behaviour | 4.2.5 | Provided |
| Protection against the ingress of foreign bodies | 4.2.6 | Provided |

| EN 54-7:2018 | | |
|----------------------------------------------------------------------------------------------|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Essential characteristics | Section | Performance |
| Response to slowly developing fires | 4.2.7 | Provided |
| Software controlled detector (when provided) | 4.2.8 | Provided |
| Nominal activation conditions/sensitivity | | |
| Repeatability | 4.3.1 | $m_{\max} / m_{\min} \leq 1,6$ $m_{\min} \geq 0,05 \text{ dB m}^{-1}$ |
| Directional Dependence | 4.3.2 | $m_{\max} / m_{\min} \leq 1,6$ $m_{\min} \geq 0,05 \text{ dB m}^{-1}$ |
| Reproducibility | 4.3.3 | $m_{\max} / m_{\text{mean}} \leq 1,33$ $m_{\text{mean}} / m_{\min} \leq 1,5$ $m_{\min} \geq 0,05 \text{ dB m}^{-1}$ |
| Response delay (response time) | | |
| Air movement | 4.4.1 | $(m_{(0,2)\max} + m_{(0,2)\min}) / (m_{(1,0)\max} + m_{(1,0)\min}) \geq 0,625$ $(m_{(0,2)\max} + m_{(0,2)\min}) / (m_{(1,0)\max} + m_{(1,0)\min}) \leq 1,6$ |
| Dazzling | 4.4.2 | $m_{\max} / m_{\min} \leq 1,6$ |
| Tolerance to supply voltage - Variation in supply parameters | | |
| | 4.5 | $m_{\max} / m_{\min} \leq 1,6$ $m_{\min} \geq 0,05 \text{ dB m}^{-1}$ |
| Performance parameters under fire conditions - Fire sensitivity | | |
| | 4.6 | TF2: $m \leq 2 \text{ dB m}^{-1}$; RT $\leq 840 \text{ s}$ TF3: $m \leq 2 \text{ dB m}^{-1}$; RT $\leq 750 \text{ s}$ TF4: $m \leq 1,73 \text{ dB m}^{-1}$; RT $\leq 180 \text{ s}$ TF5: $m \leq 1,24 \text{ dB m}^{-1}$; RT $\leq 240 \text{ s}$ |
| Durability of Nominal activation conditions/sensitivity | | |
| Cold (operational) | 4.7.1.1 | $m_{\max} / m_{\min} \leq 1,6$ |
| Dry heat (operational) | 4.7.1.2 | $m_{\max} / m_{\min} \leq 1,6$ |
| Humidity resistance | | |
| Damp heat, steady-state (operational) | 4.7.2.1 | $m_{\max} / m_{\min} \leq 1,6$ |
| Damp heat, steady-state (endurance) | 4.7.2.2 | $m_{\max} / m_{\min} \leq 1,6$ |
| Corrosion resistance - Sulfur dioxide (SO₂) corrosion (endurance) | | |
| | 4.7.3 | $m_{\max} / m_{\min} \leq 1,6$ |
| Vibration resistance | | |
| Shock (operational) | 4.7.4.1 | $m_{\max} / m_{\min} \leq 1,6$ |
| Impact (operational) | 4.7.4.2 | $m_{\max} / m_{\min} \leq 1,6$ |
| Vibration, sinusoidal (operational) | 4.7.4.3 | $m_{\max} / m_{\min} \leq 1,6$ |
| Vibration, sinusoidal (endurance) | 4.7.4.4 | $m_{\max} / m_{\min} \leq 1,6$ |
| Electrical stability - Electromagnetic Compability (EMC), Immunity test (operational) | | |
| | 4.7.5 | $m_{\max} / m_{\min} \leq 1,6$ |
| EN 54-17:2005 + AC:2007 | | |
| Essential characteristics | Section | Performance |
| Performance in the event of fire | | |
| Manufacturing tolerance | 5.2 | Passed |
| Operational reliability | | |
| Requirements | 4 | Passed |
| Stability of operational reliability, temperature resistance | | |
| Dry heat (during operation) | 5.4 | Passed |
| Cold (during operation) | 5.5 | Passed |
| Stability of operational reliability, vibration resistance | | |
| Impact (during operation) | 5.9 | Passed |
| Blow (during operation) | 5.10 | Passed |
| Oscillation, sinusoidal (during operation) | 5.11 | Passed |
| Oscillation, sinusoidal (endurance test) | 5.12 | Passed |
| Stability of operational reliability, air humidity resistance | | |
| Humid heat, cyclical (during operation) | 5.6 | Passed |
| Humid heat, constant (endurance test) | 5.7 | Passed |
| Stability of operational reliability, corrosion resistance | | |
| Sulphur dioxide (SO ₂) corrosion (endurance test) | 5.8 | Passed |

| EN 54-17:2005 + AC:2007 | | |
|-------------------------------------------------------------------------------------|----------------|--------------------|
| Essential characteristics | Section | Performance |
| Stability of operational reliability, electrical stability | | |
| Fluctuations in supply voltage | 5.3 | Passed |
| Electromagnetic compatibility (EMC), interference immunity tests (during operation) | 5.13 | Passed |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with the Construction Products Regulations 2013, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Zug, 2022-03-07

Siemens Schweiz AG

Dr. Peter Nebiker
Head of Fire Safety

Irina Penzo Feliu de Cabrera
Quality Manager Fire Safety

For signatures, see front page